

# Oil Wet Ramp Slip Resistance Test Certificate

Wednesday, 1<sup>st</sup> July 2018

Supplier: PPG Architectural Coatings (9 Birmingham Ave, Villawood, NSW, 2163)

Sample Description: Johnstone's Professional Slip Resistant Deck Oil coat on Plywood

Date Tested: June 2018 (Tested through FORAY Laboratories – NATA Accreditation 1231)

Test Method: AS/NZS 4586:2013 Appendix D "Slip resistance classification of new pedestrian surface materials – Oil Wet Inclining Platform Test Method" using Leipzig V73-SP shoes.

Test Data:

Sample Identification	Corrected mean overall acceptance angle result	Classification (Standards Australia Handbook 198)
Johnstone's Professional Slip Resistant Deck Oil coat on Plywood	22°	R11



Top view



Close up



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant



Tuan Duong  
B. Eng. (Chemical)  
Consultant

CV180709A